



Electrical Isolation

- Prior to commencing work a test for dead shall be completed.
- After any break in work or change of conditions a re-test for dead shall be completed.
- At least two people are in attendance in situations where an isolations is not possible when working close to exposed live conductors.
- Electrical isolations shall only be carried out by an authorised person(s).
- All electrical isolations shall be clearly tagged to identify the isolated electrical circuit.
- All electrical isolations shall be achieved by a physical air gap or by the use of a suitable locking device.
- Only licensed electricians or suitably authorised persons are permitted to work on electrical equipment.